



PowerTel Communications (Pvt) Ltd Head Office
 10th Floor, Joina City, Cnr Jason Moyo/ Julius Nyerere Way, P. O. Box 7600, Harare
 Tel: +263 4 780635-9, 758331, 758908, 755704, 756014, 758819 Fax: +263 4 759613,
 Contact Centre: +263 4 751263/4, 773201 Email: info@powertel.co.zw | www.powertel.co.zw

POWERTEL COMMUNICATIONS BIDDING DOCUMENT AMENDMENT 1:

TENDER: ICT/PWT/04/2021: SUPPLY AND DELIVERY OF 48 CORE G.655 OPGW FIBRE WITH FITTINGS AND ACCESSORIES FOR INSTALLATION ON HIGH VOLTAGE 330/420KV OVERHEAD POWERLINES

Please find below amendment to bidding document for OPGW Fibre.

Bidders must take note that this document becomes part of the Tender documents and will be circulated through our website to all the bidders who are participating in the tender process

No	Related RFQ Clarification	Amendment to bidding instructions
1	We want to find out if we should provide samples for each item including OPGW, accessories, etc. Please clarify the length of the sample required on the OPGW fibre.	1. There is no need for the submission of samples, bidders must provide Images and full data sheets for all the quoted items with you proposal. Please provide reference pages to where each of the specified line items are satisfied
2	Can you clarify on the mismatch on the required standard that is, the standard is G655D, but the parameters are for G652D.	2. The standard must be G655 not G652D. Please disregard the following line items that cannot be satisfied by G655 standard. <ol style="list-style-type: none"> 1. Attenuation @ 1310 2. Attenuation @1383 3. Mode field Diameter @ 1310

POWERTEL COMMUNICATIONS
 SIGNED 
 DATE 11/11/2021
 INFRASTRUCTURE PTW ENGINEER